CHATHAM COUNTY PURCHASING DEPARTMENT

FOR: HVAC Modifications at the Savannah-Chatham Metro Police Annex	

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

- 1. ADDITION: On drawing M0.1 <u>add</u> Note 5 under rooftop air conditioning units: "5. Upon activation of the room chemical suppression system the unit shall be deenergized and outside air damper shall close." This note shall apply to RTU-2A. RTU-2B and RTU-11.
- 2. CHANGE: On drawing M1.0 Note 2 <u>change</u> reference from York unit to American Standard.
- 3. CHANGE: On drawing M1.0 in Notes 2,3,5 and 6 <u>delete</u> requirement "for contractor to properly dispose of old equipment" and <u>add</u> "contractor shall remove equipment, remove all old refrigerant and place in storage area beside the building between the two (2) picnic tables. This is to include refrigerant lines."
- 4. CHANGE: On drawing M.1.0 replace Note 8 with the following:

 "8. The contractor shall install filter media over existing diffusers attached to RTU-2A and RTU-2B. Filter media shall remain in position for at least 1 week after the installation of the new roof top units. Dirty filter media shall be removed and properly disposed of prior to testing and balancing of the unit."
- 5. CHANGE: On drawing M1.1 <u>replace</u> Note 12 with the following:
 "12. All work on the roof shall maintain the roof in good condition and match roof material. The roof is not under a bond at this time.
- 6. CHANGE: On drawing M1.1 <u>add</u> the following:
 "15. Install unit hold downs to all new roof top units to match existing. Coordinate placement of hold down straps with equipment installed. Do not block access doors or condenser air flow."
- 7. CLARIFICATION: County will be responsible for the disconnect of the emergency generator run time clock and halo system.

TH BID OPENING SHALL REMAIN 2PM MAY 31, 2012.

THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

05-29-12

DATE

MARGARET H. JOYNER

PURCHASING AGENT CHATHAM COUNTY