

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 2 TO BID # 14-0131-7

FOR: Installation of Thermoplastic Polyolefin (TPO) Roofing Membrane @ the Juvenile Court Building

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

1. **CLARIFICATION:** This project will consist of leaving the existing membrane and substrate in place.
2. **CHANGE:** Section 4.2 Scope of Work, I. Roofing Conditions, #1 and #2 shall not include shall not include any reference to the removal of the existing roof.
3. **ADD:** Section 4.2 Scope of Work, A. #4 – Contractor is responsible for roof drain and screen being removed and reinstalled. Any damage to the drain or screen will be the Contractor's responsibility and will be replaced to the Owner's satisfaction.
4. **ADD:** Section 4.2 Scope of Work, L. Insulation/Underlayment - #1. When applicable, insulation shall be installed in multiple layers. The first and second layer of insulation shall be mechanically fastened to the substrate in accordance with the manufacturer's published specifications. #2. HD Polyisocyanurate – a rigid insulation panel composed of a high-density, closed-cell polyisocyanurate foam core laminated to coated-glass fiber-mat facer for use as a cover board to recover board. ½" thick 4' x 8' panel weight 11 lbs. with an R-value of 2.5.

BID DUE DATE REMAINS 2:00PM JANUARY 6, 2015.

*******THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.*******

12/22/14

DATE



MARGARET H. JOYNER
PURCHASING AGENT
CHATHAM COUNTY