

CHATHAM COUNTY PURCHASING DEPARTMENT
ADDENDUM NO. 1 TO RFP# 17-0123-7

FOR: Design, Provide and Install Playground Equipment at Three (3) Parks

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

1. **Question:** Can the pre-bid meeting date be extended?
Response: No, the pre-proposal meeting will not be extended. The pre-proposal meeting is not mandatory and any questions that arise from the meeting will be answered in the form of an addendum.
2. **Question:** Can the existing footprints for each playground be modified/expanded?
Response: Yes, the existing footprints can be modified/expanded.
3. **Question:** Is the footprint for Rio Vista where there is existing equipment or in the open area near the courts?
Response: The footprint for Rio Vista is where the existing equipment is located and not the open area near the courts.
4. **Question:** Are we allowed to relocate the existing merry-go-round, or design our structures with the existing structure in place.
Response: The existing merry-go-round can be relocated with the footprint, but must be incorporated in the playground design. Relocation of the merry-go-round will be the responsibility of the installer.
5. **Question:** Can proposers use climbing nets as well as a wall?
Response: The County would like a climbing wall and not a net.
6. **Question:** Can the pull up structure be separate?
Response: Yes, the pull up structures can be separate.
7. **CHANGE:** The following Sections of 5.3 shall now read:
 1. Westlake playground should be designed to accommodate children ranging from 5 to 12 years of age on the main playground with 2 straight slides, climbing wall, swings and pull up bars. The swings structure shall include 2 belt swings for 5 to 12 year olds and 2 bucket swings for up to 5 year olds. The swing structure shall be detached from the main play structure in accordance with ASTM and CPSC standards. The design shall also include 2 spring riders. The color theme should be nautical and appropriate signage to inform users of property safety requirements.
 2. Isle of Hope playground should be designed to accommodate children ranging from 5 to 12 years of age on the main playground with 2 straight slides, climbing wall, swings and pull up bars. The swings structure shall include 2 belt swings for 5 to 12 year olds and 2 bucket swings for up to 5 year olds. The swing structure shall be detached from the main play structure in accordance with ASTM and CPSC standards. The design shall also include 2 spring riders. The color theme should be nautical and appropriate signage to inform users of property safety requirements.
 3. The Rio Vista playground should be designed to accommodate children ranging from 5 to 12 years of age on the main playground with 2 straight slides, climbing wall, swings and pull up bars. Design will factor in an existing merry-go-round. . The swings structure shall include 2 belt

swings for 5 to 12 year olds and 2 bucket swings for up to 5 year olds. The swing structure shall be detached from the main play structure in accordance with ASTM and CPSC standards. The color theme should be natural earth tones that blend with the existing environment and appropriate signage to inform users of property safety requirements.

**THE RFP DUE DATE REMAINS 5:00 PM,
JANUARY 11, 2018.**

PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.

December 20, 2017

DATE


MARGARET H. JOYNER
PURCHASING DIRECTOR
CHATHAM COUNTY