

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 3 TO BID # 17-0038-7

FOR: RALPH MARK GILBERT CIVIL RIGHTS MUSEUM – HVAC MODIFICATIONS AND REROOF

=====

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

1. **QUESTION:** Will the County consider as a substitution for roofing material Carlisle Sure-Flex PVC Membrane?
RESPONSE: No, upon review of the product information provided it is determined that it does not meet Energy Star standard of .65 min for initial solar reflectance.

THE BID OPENING REMAINS JUNE 8, 2017.


=====

PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.

=====

May 26 2017

DATE



MARGARET H. JOYNER
PURCHASING DIRECTOR
CHATHAM COUNTY