

CHATHAM COUNTY PURCHASING & CONTRACTING DEPARTMENT

ADDENDUM NO. 2 TO 17-0124-4

FOR: 2017 RESURFACING COUNTY ROADS

PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

NOTE: Due to the Winter Storm shutdown this week here in Chatham County, the bid opening date has been extended to 2:00PM, Tuesday, January 16, 2018.

QUESTION RECEIVED:


Q). Clarification is requested on the provided typical sections for all roads without existing curb and gutter (specifically for St. Thomas Ave, Elba Lane, Denmark Dr, Adrian Ct, and McWhorter Dr). We interpret these typical sections as instructing us not to modify the existing shoulder width which is anywhere from 0 to 8 ft and just make sure that the slope beyond the shoulder is anywhere from -4:1 to +4:1. Unless ditch slopes are steeper than 4:1, no modification of ditches will be required. Is this interpretation correct?

A). The interpretation is incorrect. The roadway shoulders must slope away from the road at the grade and within the distance shown on each specific typical section. Widths are variable to allow for variations in the existing conditions. Beyond those provided distances, grading is required as necessary to tie into the existing ground at a slope no steeper than 4:1. Grading may be required on shoulders, slopes and ditch slopes depending on existing and final conditions.

**BID OPENING HAS BEEN EXTENDED TO:
2PM, TUESDAY, JANUARY 16, 2018**

THE PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

1/5/18
DATE



ROBERT E. MARSHALL
SENIOR PROCUREMENT SPECIALIST
CHATHAM COUNTY