

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO RFP #18-0045-5

**FOR: FIRING RANGE LEAD ERADICATION AND REFURBISHMENT FOR THE
CHATHAM COUNTY SHERIFF'S OFFICE**

**PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR
CHANGES:**

1. **CHANGE:** Section 5.2.3 shall read:


“Contractor shall restore soil in berms. The height of the berms is to be 15 feet above the ground and the slope of the berm is to be 1.5:1 or 33-34 degrees. The side berm height will be 10 feet and the slope of the berm is to be 1.5:1 or 33-34 degrees. The side berm will connect with the back main berm with sod or grass seed and erosion control mat. The left side berm on range 5 will be 10 feet and the slope of the berm is to be 1.5:1 or 33-34 degrees. All berms shall have sod or grass seed and erosion control mats. “

**PROPOSAL DUE DATE WILL BE EXTENDED TO
5:00PM, JUNE 28, 2018**

PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.

June 15, 2018

DATE


MARGARET H. JOYNER
PURCHASING DIRECTOR
CHATHAM COUNTY