

CHATHAM COUNTY PURCHASING DEPARTMENT  
ADDENDUM NO. 2 TO RFP #18-0047-7

**FOR: Design and Engineering Services for Replacement of 16" Force Main on Sallie Mood Drive/Agonic Road**

---

**PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:**

- Question:** Is the Level A SUE to be performed on just the county's force main at the interval specified in Addendum 1 or at the same interval on each underground utility line along the route? Instead of specifying a 200 to 400 ft. interval for Level A SUE can the County specify a set number of test holes for pricing?


**Response:** The Level A SUE is not just the force main, but the utilities along the route. As stated in Addendum 1, Level A SUE every 200' to 400' based on the nearest conflicts (i.e., driveways, intersections, existing utilities, etc.). The County will not set the number of test holes.

**THE PROPOSAL DUE DATE REMAINS 5:00 PM, JUNE 5, 2018.**

**PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.**

May 24, 2018

DATE

  
MARGARET H. JOYNER:  
PURCHASING DIRECTOR  
CHATHAM COUNTY