

CHATHAM COUNTY PURCHASING & CONTRACTING DEPARTMENT

ADDENDUM NO. 1 TO 19-0118-4

**FOR: JENNIFER ROSS SOCCER COMPLEX PARKING AND ACCESS
IMPROVEMENTS**

**PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR
CHANGES:**

**NOTE: DUE TO THE THANKSGIVING HOLIDAY SCHEDULE, THE BID OPENING
DATE HAS BEEN EXTENDED TO 2:00 PM, THURSDAY, DECEMBER 5, 2019.**

Question received:

Q) The detail for the Aggregate Surface Course on plan sheet C5 calls out for Mirafi 750X filter fabric to be installed underneath the 6" aggregate surface course. However, my geotextile supplier is saying that he nor his contact at Mirafi know what this material is. Could you please provide a specification cut-sheet for the material you would like placed underneath the ASC ?

A) The Mirafi 750x designation is one that we have used for some time. Tencate, the manufacturer, has upgraded their product line and no longer produces the x series. The 750x designation should be replaced with Mirafi HP 370 or equivalent from other manufacturers. The purpose of the fabric in this instance is separation of stone from soil.

**NOTE: BID OPENING HAS BEEN EXTENDED TO:
2:00 PM, THURSDAY, DECEMBER 5, 2019**

**THE PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES
AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.**

11/20/19
DATE


ROBERT E. MARSHALL
SENIOR PROCUREMENT SPECIALIST
CHATHAM COUNTY