

CHATHAM COUNTY PURCHASING & CONTRACTING DEPARTMENT

ADDENDUM NO. 3 TO 19-0058-4

FOR: RENOVATIONS TO 41 PARK OF COMMERCE WAY, SUITES 304-306

PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

NOTE: *Additional Questions Received* :

1.Q) Please provide carpet tile dimensions?

A) 50cm x 50cm

2.Q) Please provide LVT plank size and wear layer?

A) Size is 9"x48" 20 mil wear layer

3.Q) There is the possibility that the existing restroom tile base which is to be demo'd and then recycled will not be in suitable condition to be re-installed at new walls?

A) Base bid on reusing existing base tiles.

4.Q) Please clarify the specs for mop sink and ice maker box.


A) Mop sink and faucet are existing and remain as is. Ice maker box is Oatey 39130 or equal

NOTE: BID OPENING REMAINS:

2PM, TUESDAY, JUNE 25, 2019

THE PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

6/19/19
DATE


ROBERT E. MARSHALL
SENIOR PROCUREMENT SPECIALIST
CHATHAM COUNTY