

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO BID 20-0006-5

FOR: SHOWER VALVE REPLACEMENT AND INSTALL OF NEW COLD WATER PIPING AT THE CHATHAM COUNTY AQUATIC CENTER

=====

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

1. **Question:** What is the plan for replacing the tile around the existing shower valves? Also, what color and type of tile would we be going back with in the event we cannot find the exact same tile that is existing?

Answer: If the tile cannot be saved or matched, or a larger plate cover used to cover the damage at the shower valves, tile replacement would be needed to be the following:

The tile would be Navy 7 ¾ in. x 7 ¾ in. of the same thickness of existing tile. Installed in the following pattern:

Women's Locker Room:

2 partitioned stalls would need 4 tiles replaced to create a centered right to left look for the shower valve

2 partitioned stalls would need 6 tiles replaced to create a centered right to left look for the shower valve

4 open stalls would need 2 continuous rows of tile replaced 23 per row, 46 total to create a continuous look for the 4 shower valves

This option will negate any need to remove any stall partitions.

Men's Locker Room:

2 partitioned stalls would need 4 tiles replaced to create a centered right to left look for the shower valve

2 partitioned stalls would need 6 tiles replaced to create a centered right to left look for the shower valve

4 open stalls would need 2 continuous rows of tile replaced 23 per row, 46 total to create a continuous look for the 4 shower valves

This option will negate any need to remove any stall partitions.

Bids may be E-mailed or faxed. If you e-mail, please confirm that Purchasing has received your bid. E-mail to the Purchasing contact listed in the bid and copy Crystal King Hester at ckhester@chathamcounty.org.

Purchasing will open bids at the designated time and bidders may listen to the public opening via conference call. Bid tabulations will be posted within 24 hours.

To call in to the pre-bid or bid opening, call 1-888-585-9008 Conference Room 743-636-882.

**BID DUE DATE WILL BE EXTENDED TO 2:00PM
APRIL 8, 2020**

BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.

04/03/2020

DATE

MARGARET H. JOYNER
PURCHASING DIRECTOR
CHATHAM COUNTY