

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO BID# 21-0057-5

FOR: PURCHASE AND INSTALLATION OF A GENERATOR AND ASSOCIATED EQUIPMENT

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

1. **Question:** Can the building's electrical service be shut down for days to install the T-Switch?

Answer: The building can only be shut down for one day for connection because there are coolers and freezers that cannot be down more than one day.

BID DUE DATE WILL REMAIN 2:00PM, MAY 13, 2021

BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.

May 11, 2021

DATE



MARGARET H. JOYNER
PURCHASING DIRECTOR
CHATHAM COUNTY