

CHATHAM COUNTY PURCHASING & CONTRACTING DEPARTMENT

ADDENDUM NO. 1 TO 21-0066-4

FOR: CONSTRUCTION OF TWO METAL BUILDINGS AND BREEZEWAY AT THE CHATHAM COUNTY FIRING RANGE

PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR CHANGES:


1. Replace **page 21** of the **ITB** with the **attached revised page**. (1 sheet)
2. Replace current Bid Sheet with the **attached revised Bid Sheet**. (1 sheet)
3. See attached sheet for Responses to Questions received. (1 sheet)

NOTE: Deaadline for submitting questions is 11:00am, May 25, 2021. Any questions received after that time will be discarded.

BID OPENING REMAINS: 2PM, WEDNESDAY, JUNE 2, 2021

THE PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

5/14/21
DATE



ROBERT E. MARSHALL
SENIOR PROCUREMENT SPECIALIST
CHATHAM COUNTY

**CONSTRUCTION OF TWO METAL BUILDINGS AND A BREEZEWAY AT THE
CHATHAM COUNTY FIRING RANGE**

SPECIFICATIONS FOR:

BID NO. 21-0066-4

4.1 GENERAL SPECIFICATIONS:

The purpose of the bid is to solicit competitive bids from qualified contractors to construct two metal building and a breezeway at the Chatham County Sheriff's Office Range. For additional information concerning these specifications, please contact **ONLY** Mr. Robert Marshall, Senior Procurement Specialist, at **rmarshall@chathamcounty.org**. Bidders are not to contact any County Department directly. Detailed specifications are as follows:

4.2 BUILDING SPECIFICATIONS:

- 4.2.1 Construct and install a 40 x 40 x 12 Training building #4 using 40 year painted metal. To include 1 set of double steel doors, a single steel door and two 3 x 5 windows.
- 4.2.2 Construct and install a 30 x 32 x 14 breezeway using cold form steel and 40 year painted metal.
- 4.2.3 Construct and install a 60 x 120 x 16 metal building that will be enclosed on three sides, using 40 year painted metal. Also to include 3 steel doors.
- 4.2.4 Chatham County will handle all electrical work.

4.3 CONTRACT SPECIFICATIONS:

- 4.3.1 Bids shall be evaluated based on the requirements set forth in this solicitation, which includes bidder responsiveness, capability, past performance and other criteria to determine acceptability such as inspection, testing, quality workmanship, delivery and suitability for this purchase.
- 4.3.2 Vendor is required to provide a minimum of three (3) references related to the specifications proposed.
- 4.3.3 Materials, installation and shipping costs should be included in the total cost.

Rev. 05/14/21 Ad. 1

CHATHAM COUNTY, GEORGIA

BID

BID NO. 21-0066-4

**CONSTRUCTION OF TWO METAL BUILDINGS AND A BREEZEWAY AT THE
CHATHAM COUNTY FIRING RANGE**

Item No.	Description	QTY	Total
1	Construction and installation of a 40x40x12 Training building #4	1 Each	
2	Construction and installation of a 30x32x14 breezeway	1 Each	
3	Construction of a 60x120x16 metal building	1 Each	
		TOTAL	\$

**ALL FIRMS REQUESTING TO DO BUSINESS WITH CHATHAM COUNTY MUST REGISTER ON-LINE AT
[HTTP://PURCHASING.CHATHAMCOUNTY.ORG](http://PURCHASING.CHATHAMCOUNTY.ORG)**

NAME/TITLE

COMPANY NAME

ADDRESS

CITY/STATE/ZIP

PHONE/FAX NUMBER

EMAIL

Bid No. 21-0066-4

RESPONSES TO QUESTIONS RECEIVED:

1. Q) What is time of completion?
A) 120 days from the "notice to proceed" letter.
2. Q) Roof slope ?
A) To match existing (4/12 possibly 5/12)
3. Q) R-panel (screw down roof), or standing seam panel ?
A) R-panel (screw down)
4. Q) The 60'x120' building is sheeted on 3 sides. Please clarify sides and ends to be sheeted (eg) 2 sides & 1 end or 2 ends & 1 side
A) Close in the 2 (two) 60' sides and 1 (one) 120' side.
5. Q) Gutter & downspouts ?
A) No.
6. Q) Is roof colored or galvalume?
A) Roof color is brown on the 40x40 and galvalume on the 60x120
7. Q) Walk door hardware--type of lockset (lever or panic), Is closer device needed?
A) Lever style lockset and no closer.